



## EVESHAM TOWNSHIP FIRE DISTRICT NO. 1

*Fire Prevention Division*

P.O. Box 276 – 984 Tuckerton Road – Evesham, New Jersey 08053-0276 – 856-983-2210

**RECEIVED**

**To:** Ms. Jennifer Newton – Administrative Officer  
**From:** Deputy Chief Scott Freedman, Fire Marshal  
**Date:** June 13, 2025  
**Subject:** P25-08: PSEG Cox's Corner & Sharp Road Switch Station (Block 15, Lot 2)

**JUN 16 2025**

Regarding the above matter, Evesham Fire-Rescue is requesting the following items:

1. All fire access roads are to comply with Section 502.2.3 of the International Fire Code, 2021 Edition. Fire apparatus access road surfaces shall be designed and maintained to support the imposed loads of fire apparatus and shall be surfaced so as to provide all-weather driving capabilities. Fire access roads are to support the weight of a fire truck at 75,500 pounds.
2. The site plan shows a series of security gates limiting access to the site. It is presumed these gates will be locked; however, the site plan does not indicate the method for locking said access gates. The security gates to the complex are to be made accessible for the fire department to access in an emergency, meaning the gates shall have an approved means of emergency operations.
3. Premises identification: ensure the entrance to the property indicates the site name and address.
4. A Knox Box key access system may need to be supplied to address access to the property noted in Item #2.